



COMPLIANCE

with IEC EN 61508:2010

Certificate No.: C-IS-269080-02

CERTIFICATE OWNER:

PENTA s.r.l.

Via G. Boccaccio, 23

25080 - Molinetto di Mazzano (BS) - Italy

WE HEREWITH CONFIRM THAT

THE TRUNNION BALL VALVES SERIES:

APT2 - SAT/APT3 - SAT CRIO - 3WAY

MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLE

FOR THE SAFETY FUNCTIONS:

"correct switching on demand (open to closed and closed to open), in low demand mode of operation"

"correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"

Examination result: The above reported TRUNNION BALL VALVES were

> found to meet the standard defined requirements of the safety levels detailed in the following table (T -IS - 269080 - 02) according to IEC EN 61508:2010, under fulfillment of the conditions listed in the Report R-IS-269080-02 Rev.1 dated April, 21st 2016 in its currently valid version, on which this

Certificate is based

Construction/Functional characteristics **Examination parameters:**

reliability and availability parameters of the above

mentioned TRUNNION BALL VALVES

R-IS-269080-02 Rev. 1 Official Report No.:

May, 02nd 2019 **Expiry Date**

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT

THE PRESENT DOCUMENT SUBSITUTES AND REPEALS THE DOCUMENTS C-IS-260464-02

IEC EN 61508:2010 Part 2, 4, 6, 7 Reference Standard

Sesto San Giovanni, April, 21st 2016





SUMMARY TABLE T - IS - 269080 - 02

E/EE/EP safety-related system (final element)	TRUNNION BALL VALVES produced by PENTA S.r.l. Type A	
System type		
Safety Function Definition	Complete switching on demand (open to closed / closed to open) in low demand mode of operation	Complete switching on demand (open to closed) and sealing in closed position in low demand mode of operation
Max SIL ⁽¹⁾	SIL3	SIL3
Additional requirements for the max SIL classification	Execution of Automatic Partial Stroke Test with time interval not higher than 9 months and Full Proof Test with time interval not higher than 12 months	Execution of Automatic Partial Stroke Test with time interval not higher than 9 months and Full Proof Test with time interval not higher than 12 months
$\lambda_{ ext{TOT}}$	3,579E-07	5,248E-07
λ_{SU}	2,255E-07	3,924E-07
λ_{SD}	0,000E+00	0,000E+00
$\lambda_{\mathrm{DD,PST}}$	1,178E-07	8,148E-08
$\lambda_{\mathrm{DU,FPT}}$	1,459E-08	5,058E-08
$PFD^{(2)}$	4,670E-04	4,904E-04
β and β_D factor	5%	5%
MRT	8 h	8 h
Hardware Safety Integrity	Route 2 _H	Route 2 _H
Systematic Safety Integrity	Route 2 _S	Route 2 ₈

- (1) The Safety Integrity Level (SIL) of an entire SIF must be verified with the calculation of the PFDavg considering the architectural constraints (Route 2H), proof test interval, any automatic diagnostics and the failure rates of all products included in the SIF.
- (2) PFD of reference calculated on the basis of a Full Proof Test and Automatic Partial Stroke test with time interval reported in the line Additional requirements for the max SIL classification. This time intervals are considered by TÜV as reasonably consistent with the implementation of the equipment for safety related-applications, with reference to the overall range of results shown in the report, where other possible combination of time intervals adequate for a classification up to SIL 2 or SIL3 are reported. Note that, concerning Full Proof Tests, time intervals for higher than 36 months are considered by TÜV as not adequate and consistent for equipment for safety related applications.

SIL classification according to Standards IEC EN 61508:2010 (Chapters: 2, 4, 6, 7) for Trunnion Ball Valves produced by PENTA S.r.l.



NOTE : The present table is integral part of the document C–IS–269080-02 Date : April, 21st 2016