Certificate no: Page 1 of 1

MLN0501651/1



Project:

Client: PENTA srl - MOLINETTO (BS) - ITALY

Office: Milan

Clients Order Number: Fax dd. 22/07/2005

14 December 2005

Order Status: Complete

Inspection Dates

First: 18 November 2005

14 December 2005

This certificate is issued to PENTA srl - MOLINETTO (BS) - ITALY

to certify that Mr. G. RENIER Inspector to this Society did, at their request, attend their Works at Casorezzo (Milan) - Italy, for the purpose of witnessing the Fire Safe Test according to API 607 V Ed. June 2005/EN ISO 10497 Ed. Aug.2004, on the following ball valve, manufactured by PENTA S..r.l. Molinetto (BS)- Italy:

DN 50 (2") ANSI 300 CARBON STEEL BALL VALVE - TYPE AP60 TO DRAWING NO. 85900-DPL REV. 0 DATED 2/11/2005

The ball valve was tested accordance with above specification.

Test apparatus, test procedure and test results, as described in Fire Safe Test Report No.: 0511, dated 18/11/2005, endorsed by the undersigned, were found within the requirements of API 607 V Ed. - June 2005/EN ISO 10497 Ed. Aug. 2004.

The valve has passed the fire safe test.

d's Register EMEA TICE US Register EMEA A member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract. Form 1123 (2005.02)