

Project: -

Client: PENTA Srl - MOLINETTO (BS) - ITALY

Office: Milan

Clients Order Number: e-mail dd. 12/03/2012

Date: 07 May 2012

Order Status: Complete

Inspection Dates

First: 02 May 2012

Final: 02 May 2012

This certificate is issued to PENTA srl - MOLINETTO (BS) - ITALY

to certify that Mr. G. RENIER Inspector to this Society did, at their request, attend their Works at Casorezzo (Milan) Italy, for the purpose of inspecting the Fire Safe Test according to API 6FA -1999 ed. and API 607 Fifth Edition June 2005/EN ISO 10497:2010, on the following ball valve, manufactured, by PENTA S. R.L. - Molinetta (BS) - Italy:

DN 50 (2") ANSI 1500# - CARBON STEEL METAL SEATED BALL VALVE TYPE FB SAT TR
TO DRAWING NO. H55200-DPL REV. 0 DATED 13.04.2012

The ball valve was tested in accordance with above specification

The test apparatus, test procedure and test results, as described in Fire Safe Test Report no. 12/001, dated 02/05/2012, endorsed by the Undersigned, were found within the requirements of API 6FA -1999 ed. and API 607 Fifth Edition June 2005/EN ISO 10497:2010.

The ball valve has passed the fire safe test.

G. RENIER
Inspector to Lloyd's Register EMEA
Milan Office
A member of the Lloyd's Register Group

